

**INSPECTION REPORT**

Report number 70450007-TDT 04-42066A  
Client SVET.CTQC  
Shenyang Hunnan New & High-Tech. Industrial  
Development Zone  
Shenyang 110179  
China  
Reference Trust testing  
Concerning routine, type and special tests  
Date between January 5 and January 10, 2004  
Place Shenyang, China  
Object Power Transformer 1600 kVA  
Manufacturer Hangzhou Qianjiang Electric Group Co., Ltd.

**REQUIREMENTS**

Requirements as specified in the standards IEC 60076-1, IEC 60076-2, IEC 60076-3, IEC 60076-5 and IEC 60076-10.

**TEST PROGRAMME**

The programme was specified by the client.  
For the programme we refer to page 3.

**SUMMARY AND CONCLUSION**

The results obtained relate only to the work ordered and to the material tested.  
On the points examined, the requirements specified for the material tested were met.

Author G.J. Veldscholten

KEMA Nederland B.V.

This B-report consists of:  
17 pages  
4 annexes  
1 appendix (31 pages)

  
A.J.G. Klomp  
KEMA T&D Testing Services

Arnhem, May 14, 2004

© Copyright: Publication or reproduction of the contents of this report in any other form than a complete copy to the letter, is not allowed without our written consent.

**MATERIAL DATA**

Manufacturer	Hangzhou Qianjiang Electric Group Co., Ltd.
Type	S11-1600/10
Serial number	0307510001
Rated power	1600 kVA
Rated voltages	10 / 0.4 kV
Rated current	92.4/2309.4 A
Rated frequency	50 Hz
Number of phases	3
Tapping range	+5%, -5%
Number of steps/ tapping step	3 / 5%
Vector group	Yyn0
Cooling method	ONAN
Temperature class of insulation	A
Insulation levels	H.V. LI/LIC/AC – 75 / 85 / 35 kV L.V. AC – 5 kV
Short-circuit impedance	4.5%
Total mass	4680 kg

**TEST OBJECT IDENTIFICATION**

The test object was identified by checking the rating plate and the serial number.

During the untanking operation the test object was checked with the drawings enclosed in the SVET.CTQC report number CTQC/B-04.001.

The SVET.CTQC test report regarding tests, oscillograms, curves, lists of test equipments, test circuits and manufacturer drawings are enclosed in this report as appendix A.

## TEST PROGRAMME

		kind of test *	standard/ specification	clause
0	INSPECTION OF THE TEST SET-UP			
1	ROUTINE-, SPECIAL- AND TYPE TESTS BEFORE SHORT-CIRCUIT TEST			
1.1	Separate source AC withstand voltage test	R	IEC 60076-3	5,11
1.2	Short-duration induced AC withstand voltage test	R	IEC 60076-3	5,12
1.3	Measurement of insulation resistances	S	IEC 60076-1	10.1
1.4	Measurement of winding resistance	R	IEC 60076-1	10.2
1.5	Measurement of voltage ratio and check of voltage vector relationship	R	IEC 60076-1	10.3
1.6	Measurement of load loss and short-circuit impedance	R	IEC 60076-1	10.4
1.7	Measurement of zero sequence impedance	S	IEC 60076-1	10.7
1.8	Measurement of no-load loss and current	R	IEC 60076-1	10.5
1.9	Measurement of the harmonics of the no-load current	S	IEC 60076-1	10.6
1.10	Temperature-rise test	T	IEC 60076-2	
1.11	Determination of sound levels	S	IEC 60076-10	
1.12	Test on transformer oil			
2	SHORT-CIRCUIT TEST	S	IEC 60076-5	
3	REPEAT OF ROUTINE TESTS, SPECIAL- AND TYPE TESTS			
3.1	Separate source AC withstand voltage test	R	IEC 60076-3	5, 11
3.2	Short-duration induced AC withstand voltage test	R	IEC 60076-3	5, 12
3.3	Measurement of insulation resistances	S	IEC 60076-1	10.1
3.4	Measurement of winding resistance	R	IEC 60076-1	10.2
3.5	Measurement of voltage ratio and check of voltage vector relationship	R	IEC 60076-1	10.3
3.6	Measurement of no load loss and current	R	IEC 60076-1	10.5
3.7	Measurement of load loss and impedance	R	IEC 60076-1	10.4
3.8	Lightning impulse test (including chopped)	T	IEC 60076-3	13
3.9	Test on transformer oil			
3.10	Inspection of the active part	S	IEC 60076-5	4.2

R = routine test T = type test S = special test

**PERSONS ATTENDING THE TEST**

Mr Chen Kui	SVET.CTQC
Mr Tian Wenge	SVET.CTQC
Mr Wang Maosong	SVET.CTQC

**THE INSPECTION WAS CARRIED OUT BY**

Mr A.B. Hofstee	KEMA Nederland B.V.
Mr G.J Veldscholten	KEMA Nederland B.V.

**PURPOSE OF THE TEST**

Purpose of the test was to verify whether the material, regarding the routine-, type- and special tests in accordance with the test programme, complies with the specified requirements.

**DESCRIPTION AND RESULTS OF THE TESTS PERFORMED****0 INSPECTION OF THE TEST SET-UP**

The tests were carried out in the laboratory of SVET, who is therefore jointly responsible for the correctness of the results obtained. The measuring devices and the test set-up were checked by us and where necessary calibrated.

**Results**

The inspection did not give rise to remarks.

**1 ROUTINE-, TYPE- AND SPECIAL TESTS BEFORE SHORT-CIRCUIT TEST****1.1 Separate source AC withstand voltage test**

The tests were carried in accordance with IEC 60076-3 clause 11.

The high voltage winding was tested with 35 kV, 50 Hz for 1 minute. The low voltage winding was tested with 5 kV, 50 Hz for 1 minute.

**Results**

Values of the applied voltages are higher than the IEC standard. No collapse of the test voltages occurred.

**1.2 Short-duration induced AC withstand voltage test**

The test was carried out in accordance with IEC 60076-3 clause 12.

A three-phase power-frequency voltage of 200 Hz was applied to the low-voltage winding during 30 seconds in order to induce 200%  $U_n$ . The tapping position during the test was 2 (10000/400 V).

## Results

No collapse of the test voltages occurred.

### 1.3 Measurement of insulation resistances

Measured was the insulation resistance between the mutual windings and between the winding and ground with a d.c. voltage of 5 kV. The measured values are shown in annex 1.

## Results

The measured values do not give rise to remarks.

### 1.4 Measurement of winding resistance

The measurement was carried out in accordance with IEC 60076-1 clause 10.2. The d.c. resistance of the windings was determined with equipment, measuring voltages and currents and calculating the measured resistance. The resistances of the h.v. winding were measured in all positions of the tap-changer. The results of the measurements are represented in annex 1.

## Results

The measured values do not give rise to remarks.

### 1.5 Measurement of voltage ratio and check of voltage vector relationship

The measurement was carried out in accordance with IEC 60076-1, clause 10.3. The voltage ratio was measured using a bridge circuit at low voltage. The measurements took place for all tapping positions. The connection symbol was checked together with the determination of the voltage ratio. Balance of the bridge can be attained only if the voltages connected to the bridge from the primary and secondary side have the same phase and sense. The measured values in comparison with the specified ones are given in annex 1.

## Results

The deviations with respect to the rated values are within the specified tolerances.

### 1.6 Measurement of load loss and short-circuit impedance

The measurement was carried out in accordance with IEC 60076-1 clause 10.4. The load loss and the short-circuit impedance were measured with a three phase supply. The measurements took place in all tapping positions. The l.v. winding was short-circuited. The measuring results were recalculated to 75 °C winding temperature and are given in annex 1.

## Results

The measured values were within the specified tolerance.

### 1.7 Measurement of zero sequence impedance

The measurement was carried out in accordance with IEC 60076-1, clause 10.7, measured in tapping position 2. There is no value specified for this impedance. The measured values are given in annex 3.

## Results

The measured values do not give rise to remarks.

### 1.8 Measurement of no-load loss and current

The measurement was carried out in accordance with IEC 60076-1, clause 10.5. The no-load loss and no-load currents were measured with supply at the low voltage side with rated voltage. The results in comparison with the specified values are given in annex 1.

**Results**

The measured values were within the specified tolerance.

**1.9 Measurement of the harmonics of the no-load current**

The harmonics of the no-load current were measured at nominal voltage. The measured values are given in the SVET.CTQC report, see appendix A.

**Results**

The measured values don't give rise to remarks.

**1.10 Temperature-rise test**

The temperature-rise test was carried out in accordance with IEC 60076-2. The transformer was loaded with its total losses (no-load loss and load loss) of tap 2. The measured values, compared with the guaranteed values, are given in annex 2.

**Results**

The measured temperature-rise values are well below the allowed maximum values.

**1.11 Determination of sound levels**

The sound level test was carried out in accordance with IEC 60076-10. Sound level measurement was carried out at 100% of the rated voltage. The measurement was carried out indoors. The measured values are given in annex 3.

**Results**

The measured values, compared with the guaranteed values, don't give rise to remarks.



### 1.12 Test on transformer oil

The transformer oil was checked upon breakdown voltage and  $\tan \delta$  at 90 °C.

#### Results

Breakdown voltage was 55.2 kV, while requirement was higher than 35 kV.

Tan  $\delta$  was 0.0009 while requirement was less than 0.01.

## 2 SHORT-CIRCUIT TEST

The short-circuit test was carried out in accordance with IEC 60076-5. The transformer is of category 1.

Calculations of the short-circuit current were made with a short-circuit rating of 500 MVA and a system voltage of 10 kV.

The test was performed according to the single-phase method. The single-phase supply is provided between one terminal and to the other two terminals connected together. The secondary windings were shorted.

The primary, secondary and tank currents were measured.

After each test the reactance of the windings were measured at the primary side.

The measured and calculated values of currents and reactance are given in the SVET.CTQC report, see appendix A.

#### Results

During the test no visible damage could be detected.

The reactance deviations were within the tolerance.

The currents and peak currents were within the tolerances.

### **3 REPEAT OF ROUTINE TEST**

#### **3.1 Separate source AC withstand voltage test**

The tests were carried out in accordance with IEC 60076-3 clause 11.

The high voltage winding was tested with 35 kV, 50 Hz for 1 minute. The low voltage winding was tested with 5 kV, 50 Hz for 1 minute.

#### **Results**

Values of the applied voltages are higher than the IEC standard. No collapse of the test voltages occurred.

#### **3.2 Short-duration induced AC withstand voltage test**

The test was carried out in accordance with IEC 60076-3 clause 12.

A three-phase power-frequency voltage of 200 Hz was applied to the low-voltage winding during 30 seconds in order to induce 200%  $U_n$ . The tapping position during the test was 2 (10000/400 V).

#### **Results**

No collapse of the test voltages occurred.

#### **3.3 Measurement of insulation resistances**

Measured was the insulation resistance between the mutual windings and between the winding and ground with a d.c. voltage of 5 kV. The measured values are shown in annex 4.

#### **Results**

The measured values do not give rise to remarks.

### 3.4 Measurement of winding resistance

The measurement was carried out in accordance with IEC 60076-1 clause 10.2. The d.c. resistance of the windings was determined with equipment, measuring voltages and currents and calculating the measured resistance. The resistances of the h.v. winding were measured in all positions of the tap-changer. The results of the measurements are represented in annex 4.

#### Results

The measured values do not give rise to remarks.

### 3.5 Measurement of voltage ratio and check of voltage vector relationship

The measurement was carried out in accordance with IEC 60076-1, clause 10.3. The voltage ratio was measured using a bridge circuit at low voltage. The measurements took place for all tapping positions. The connection symbol was checked together with the determination of the voltage ratio. Balance of the bridge can be attained only if the voltages connected to the bridge from the primary and secondary side have the same phase and sense. The measured values in comparison with the specified ones are given in annex 4.

#### Results

The deviations with respect to the rated values are within the specified tolerances.

### 3.6 Measurement of no-load loss and current

The measurement was carried out in accordance with IEC 60076-1, clause 10.5. The no-load loss and no-load currents were measured with supply at the low-voltage side with rated voltage. The results in comparison with the specified values are given in annex 4.

## Results

The measured values were within the specified tolerance.

### 3.7 Measurement of load loss and short-circuit impedance

The measurement was carried out in accordance with IEC 60076-1 clause 10.4. The load loss and the short-circuit impedance were measured with a three phase supply. The measurements took place in tap 2. The l.v. winding was short-circuited. The measuring results were recalculated to 75 °C winding temperature and are given in annex 4.

## Results

The measured values were within the specified tolerance.

### 3.8 Lightning impulse test (including chopped)

The test was carried out in accordance with IEC 60076-3, clause 13. The lightning impulse test voltage was 75 kV and the chopped wave was 85 kV. The three phases of the high voltage windings were each tested with a sequence consisting of one reduced full wave, one full wave, one reduced chopped wave, two chopped waves and two full waves all of negative polarity. The results are given in the SVET.CTQC report, see appendix A.

## Results

The transformer passed the test successfully.

### 3.9 Test on transformer oil

The transformer oil was checked upon breakdown voltage and  $\tan \delta$  at 90 °C.

**Results**

Breakdown voltage was 55.12 kV, while requirement was higher than 35 kV.

Tan  $\delta$  was 0.0012 while requirement was less than 0.01.

**3.10 Inspection of the active part**

The transformer was untanked and the active part was inspected.

The out-of-tank inspection with respect to displacements, deformations of core and windings, connections and supporting structures or traces of discharges did not reveal any apparent defects.

The drawings and photos made before and after short-circuit test can be found in the SVET.CTQC report, see appendix A.

**Results**

The transformer complies with IEC 60076-5, sub-clause 4.2.7.

Annex 1

**Results of routine tests before the short-circuit tests.**

Transformer number: 0307510001.

**Insulation impedance**

Humidity: 33%, oil temperature 12 °C	
Measurement position	Insulation resistance (GΩ)
H.V. – L.V. & tank to earth	70.1
L.V. – H.V. & tank to earth	35.0
H.V. & L.V. – tank to earth	60.1

**Winding resistances**

Resistance at 12.0 °C	H.V. voltage (Ω)			L.V. (mΩ)
	Tap 1	Tap 2	Tap 3	
A-B (a-b)	0.3777	0.3584	0.3389	0.7563
B-C (b-c)	0.3773	0.3582	0.3387	0.7549
C-A (c-a)	0.3778	0.3585	0.3390	0.7667

**Ratio and connection group**

H.V.		L.V.	Ratio	Measured deviation (%)			Connection group
Tap position	Voltage (kV)	Voltage (kV)		AB/ab	BC/bc	CA/ca	
1	10.50	0.40	26.25	0.00	0.00	0.00	Yyno
2	10.00		25.00	0.01	0.01	0.01	
3	9.50		23.75	0.00	0.00	0.01	

**No-load loss**

Rated no-load voltage	Average current (A)	Average current (%) / guaranteed (%)	No-load loss (W) / guaranteed
400 V	2.28	0.10 / 0.6	1380 / 1640

**Load loss**

Values calculated to 145 °C	Tap 1	Tap 2	Tap 3
Load loss (W) / guaranteed	14520 / -	14750 / 14500	15020 / -
Impedance (Ω)	3.41	3.05	2.68
Impedance (%) / guaranteed	4.95 / -	4.88 / 4.50	4.76 / -

**Results of the temperature rise test.**

Transformer number: 0307510001.

		required/ [max. allowed]
<b>GENERAL</b>		
Power	kVA	1600
Cooling		ONAN
Position of tap changer		2
Ratio	kV	10/ 0.4
Supplied losses (sum of load and no-load losses at 75 °C)	kW	16.35
<b>RESULTS TEMPERATURE-RISES</b>		
Top-oil	K	47.6 / [55 ]
Mean oil	K	35.7
Mean high voltage windings	K	52.7 / [65]
Mean low voltage windings	K	59.7 / [65]

Annex 3

**Measurement of sound levels.**

Transformer number: 0307510001.

Location		Indoor
Excitation	% U <sub>n</sub>	100
Cooling method		ONAN
Number of measuring points		
At 1/2 height		10
Measuring distance	m	0.3
Logarithmic mean of		
Measured value	dB <sub>A</sub>	41.8
Corrected measuring result	dB <sub>A</sub>	41
Calculated sound power	dB <sub>A</sub>	54
Guaranteed sound power	dB <sub>A</sub>	65

**Zero sequence impedance.**

Connection group	Applied voltage terminal	Open circuit terminal	Short-circuit terminal	Applied current (A)	Measured voltage (V)	Losses (kW)	Impedance (Ω)
Yyn0	abc - 0	A, B, C	/	461.3	15.6	3.5	0.1015
				922.5	28.8	12.0	0.0937
				1385.0	40.8	26.0	0.0884
				1847.5	52.0	43.0	0.0845
				2310	60.0	67.0	0.0779



**Results of routine tests after the short-circuit tests.**

Transformer number: 0307510001.

**Insulation impedance**

Humidity: 28%, oil temperature 11.4 °C	
Measurement position	Insulation resistance (GΩ)
H.V. – L.V. & tank to earth	54.7
L.V. – H.V. & tank to earth	28.1
H.V. & L.V. – tank to earth	47.5

**Winding resistances**

Resistance at 11.4 °C	H.V. (Ω)			L.V. (mΩ)
	Tap 1	Tap 2	Tap 3	
A-B (a-b)	0.3764	0.3574	0.3383	0.7575
B-C (b-c)	0.3761	0.3572	0.3382	0.7576
C-A (c-a)	0.3764	0.3575	0.3384	0.7688

**Ratio and connection group**

H.V.		L.V.	Ratio	Measured deviation (%)			Connection group
Tap position	Voltage (kV)	Voltage (kV)		AB/ab	BC/bc	CA/ca	
1	10.50	0.40	26.25	0.00	0.01	0.01	Yyno
2	10.00		25.00	0.01	0.01	0.02	
3	9.50		23.75	0.00	0.01	0.01	

**No-load loss**

Rated no-load voltage	Average current (A)	Average current %)/ guaranteed(%)	No-load loss (W)/ guaranteed
400 V	2.30	0.10 / 0.6	1390 / 1640

**Load loss**

Values calculated to 145 °C	Tap 1	Tap 2	Tap 3
Load loss (W)/ guaranteed		14640/ 14500	
Impedance (Ω)		3.04	
Impedance (%)/ guaranteed		4.86/ 4.50	

**REPORT OF TESTS WITNESSED**

**REPORT No.** 4007-04  
**PROJECT No.** 70450007

**APPARATUS** A power transformer  
**DESIGNATION** S11-1600/10 **SERIAL No.** 0307510001  
**CLIENT** Hangzhou Quinjiang Electric Group Co. Ltd., Hangzhou, P.R.China  
**MANUFACTURER** Hangzhou Quinjiang Electric Group Co. Ltd., Hangzhou, P.R.China  
**RATINGS**  
**Voltage** 10 kV  $\pm$  5% / 400 V  
**Power** 1600 kVA  
**Short-circuit impedance** 4,5 %  
**Connection symbol** Yyn0  
**Cooling method** ONAN  
**Frequency** 50 Hz  
**Temperature class of insulation** A

**TEST LOCATION** SVET, Shenyang, P.R. China  
**DATE(S) OF TESTS** 4<sup>th</sup> January 2004  
**TEST SPECIFICATION** IEC 60076

**SUMMARY AND CONCLUSION**

KEMA has witnessed the tests carried out at the laboratory of SVET:

- Routine tests
- Type tests
- Special tests

The results obtained relate only to the work ordered and to the material inspected. For the points examined the requirements of the standard mentioned were met.

SVET has compiled a document no. CTQC/B-04.001 forming part of this Report of Type Test Witnessed. KEMA has verified that this document is a true record of the tests performed. The ultimate responsibility for correctness and the accuracy of test results remains with the laboratory.

The report applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested, rests with the Manufacturer.

© Copyright: Only integral reproduction of this report, or reproductions of this page accompanied by any page(s) on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this report may be available and have the status "for information only".  
The sealed and bound version of the report is the only valid version.

KEMA Nederland B.V.



P.G.A. Bus  
Manager High-Power Laboratory

Arnhem, 19<sup>th</sup> March 2004